

Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# Retrofit G6-300 / G6-400 + InvencoLink Wayne Helix Standard (US and Canada) Installation Guide

Kit Part Numbers	Brief Description
RF00079-XX	G6-300 / G6-400 Wayne Helix Standard, Black



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# **Release History**

Version	Prepared by	Date	Change description
0	Jojie Adigue & Michael Doh	Apr 2021	New document based on DCV-00540 R03
1	Michael doh	08-Jun-21	Updated from UL review
2	Michael Doh	22-Jun-21	Corrected step 6 of section 4.3.1
3	Michael Doh	18-Jul-21	Clarified wording relating to the number of sides that can be installed per dispenser.
4	Shibani Joshi	25-Jan-2022	Changed the power supply P/N from EZ0632 to EZ0704
5	Shibani Joshi	03-Feb-23	Added content for G6-400 OPT installation and updated PSU to EZ0853 with the two power cable connections
6	Shibani Joshi	19-June-2023	UL Comments Addressed. No BoM changes.

© 2023 by Invenco Group Limited All rights reserved No part of this document may be copied or reproduced in any form without prior written consent from Invenco. Invenco has taken great effort to verify the accuracy of this document but assumes no responsibility for any technical inaccuracies or typographical errors



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

### Contents

R	elease	Hist	ory	2
1	Intro	oduct	ion	5
	1.1	Тоо	Is Required	7
	1.2	Insta	allation Kit Contents	8
2	Safe	ety &	Compliance Information	12
	2.1	Prel	iminary Precautions	12
	2.2	Eme	ergency Total Electrical Shut-Off	12
	2.3	Tota	I Electrical Shut-Off Before Access	12
	2.4	Eva	cuation, Barricading and Shut-Off	12
	2.5	Rea	d the Manual	12
	2.6	Follo	ow the Regulations	13
	2.7	Rep	lacement Parts	13
3	Safe	ety S	ymbols and Terminology	13
	3.1	Prev	ent Explosions and Fires	14
	3.1.	1	No Open Flames	14
	3.1.	2	No Sparks - No Smoking	14
	3.1.3	3	Working Alone	14
	3.1.	4	Working with Electricity Safety	14
	3.1.	5	Hazardous Materials	15
	3.1.	6	In an Emergency	15
	3.1.	7	Approvals	15
	3.2	Con	nputer Programs and Documentation	16
4	Insta	allati	on Guide	17
	4.1	Disa	ssembly Procedure	17
	4.2	Pre-	Installation Procedure	18
	4.2.	1	Shut off the main power to the dispenser before beginning the deinstallation	18
	4.2.2	2	Open the dispenser.	18
	4.2.3	3	Remove the dispenser shoulders	22
	4.2.4	4	Uninstall the Helix Cabinet Components	26
	4.2.	5	Uninstall the dispenser Upper Collar Frame	41
	4.2.	6	Uninstall the metal bracket components from the dispenser	47
	4.3	Insta	all the G6-300 / G6-400 Assembly into the Wayne Helix	64
	4.3.	1	Prepare and Install the Helix Power Supply Assembly	64
	4.3.	2	Install the Collar Frame	75
	4.3.	3	Prepare to install the G6-300 / G6-400 Panel Assembly	81
	4.3.4	4	Install the G6-300 / G6-400 Panel Assembly into the Helix STD Dispenser	92



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

	4.3.5	Wiring Completion	104
5	First Pov	ver-Up	105



# 1 Introduction

The documentation provides some basic guidelines for installing the G6-300 / G6-400 Helix Standard (G6-300 / G6-400) Outdoor Payment Terminal (OPT) system:

 G6-300 / G6-400 Outdoor Payment Terminal (OPT) system, Wayne Helix Standard Dispenser (without intercom speaker), Black:
Kit part number: RF00079-XX

This Retro-Fit Kit can be installed into either Side A or Side B of a Wayne Helix dispenser.

NOTE: Two kits are required for a full installation of the G6-300 / G6-400s OPT system to the Wayne Helix dispenser. A single side installation is not possible.

CAUTION: Do not proceed unless two G6-300 / G6-400 Wayne Helix Retrofit kits are available for installation on a Helix Standard Dispenser.

• If this Kit will be installed into Side A (i.e. the first side installed), it requires the pre-installation of UL Listed by Report Retrofit Kit Part Number RF00033-XX ( (Invenco Link Converter) before installation into the dispenser. The process is covered in §4.3.2 Prepare and Install the Helix Power Supply Assembly procedure of this instruction, by reference to the instructions in that Kit.

**IMPORTANT NOTE:** The installer must review the entire installation guide prior to starting any work on the dispenser. If the construction of the dispenser in the installation guide does not match the construction of the dispenser being retrofitted, then do not proceed with the installation and contact customer service.

In particular, an earlier revision of the above Retrofit kit may not have the InvencoLink DC power cable fitted on the PSU assembly. If this is the case, stop the installation and contact technical support to obtain the correct matching revision of the kit.

Note: There are images with the OPT fitted during the installation procedure throughout the document. Depending on which kit you are installing, it could be the G6-300 or the G6-400 OPT.



Document Number	DCV-00577	
Date Released	Feb. 2023	
Revision Number/Security level	R06 S2	

Refer to the below images to identify the OPT you are working with:



G6-300 OPT

G6-400 OPT



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# 1.1 Tools Required

The following tools are required to install the G6-300 / G6-400 Wayne Helix Standard Retrofit kit:

- Torx T25 security screwdriver
- Philips #1 screwdriver
- Philips #1 screwdriver with >5" shaft
- Flat 5mm screwdriver
- Small adjustable spanner
- Side cutters
- Cable (zip) ties
- Pliers
- <sup>1</sup>/<sub>4</sub>" Socket or Nut Driver
- Small flat blade scraper or putty knife.



WARNING Do NOT use power tools if working on a fuel station forecourt.

Any spark could cause an explosion.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# 1.2 Installation Kit Contents

#### G6-300 / G6-400 Outdoor Payment Terminal (OPT) system, Black (RF00079-XX):

Unpack the G6-300 / G6-400 Wayne Helix Standard Black Retro-Fit Kit (RF00079-XX) and check that all the parts listed below are present. Also refer to the power supply assembly-installation procedure (section 4.3.) relating to the communication method parts.

Retrofit Kit Contents		
Part Number	Description	Illustration
1 x RP00079-XX	G6-300 / G6- 400 Wayne Helix Standard RFK panel assembly	
1 x EZ0853	PSU Assy for G6-300 / G6- 400	



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

1 x MP0908 (497-0517696)	Helix PSU Mounting Bracket (one per dispenser)	
1 x MP0999 (497-0521281)	Buzzer Adhesive Pad (one per dispenser)	
2 x MN0029	PSU lock nuts 7-32 UNC	
1 x MS0249 (006-8617819)	PSU Screw A (one per dispenser) 6- 32 x 0.375"	
2 x MS0146 (006-8611215)	PSU Screw B (two per dispenser) 6- 32 x ½"	
2 x MN0076 (006-8611426)	PSU Nut B (two per dispenser) 6- 32 KEP	



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

1 x MP0933 (497-0517598)	Helix Upper Plastic Collar Door Frame	
1 x MP1000 (497-0522916)	PPU Bracket	
2 x MW0058 (006-8626923)	Totalizer Spacer Washer	
1 x MZ0212	Printer Side Slide Rail Assembly	
1 x MZ0222	Card Reader Side Slide Rail Assembly	
2 x MS0245 (006-8611475)	Slide Rail Screw #6-19 x 3/8"	
2 x MN0078 (006-8611847)	Slide Rail Nut M4 KEP	
MO0023 + MO0033 (497-0515297)	Lock Assembly (Optional per installation location)	
2 x MS0280	Hi-Lo, #8-18 x 3/8", Pan Head Philips	



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

7 x MS0257 (006-8626866)	M4 x 12 Screw, Truss Head Phillips	(All spares, none used)
1 x MZ0116	G6 Hatch, Cover & Screws (8 x M3 x 6)	
1 x MF0046	Fastener, cable clip	C C C C C C C C C C C C C C C C C C C
Cable kit comprising:		
EK0130	Cable Assy, Ground, 8G fork to ¼" QC female	
1 x EK0131 (497-0513384)	Cat-5e, Flexible, YELLOW	
1 x EK0126 (497-0513686)	Wayne Pump to PSU Adaptor	
1 x EK0203 (497-0519397)	Cable Assy, Data Wayne Helix to InvencoLink	



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# 2 Safety & Compliance Information

This section introduces the hazards and safety precautions associated with installing, inspecting, maintaining or servicing the G6-300 / G6-400 OPT. Before proceeding, check the relevant hazard and safety information. Fire, explosion or electrical shock could occur and cause death or serious injury if these safe service procedures are not followed.

# 2.1 Preliminary Precautions

You are working in a potentially dangerous environment of flammable fuels, vapour, and high voltage. Only trained or authorized individuals knowledgeable in the related procedures should install, inspect, maintain or service this equipment.

# 2.2 Emergency Total Electrical Shut-Off

Locate the forecourt emergency fuel shut-off valves and electrical isolation breakers. Understand how to use these, should they be required. Locate the switch or circuit breakers that shut-off all power to all fueling equipment and dispensing devices.

# 2.3 Total Electrical Shut-Off Before Access

Any procedure requiring access to electrical components or the electronics of a pump/dispenser requires total electrical shut-off of that unit. Understand the function and location of this switch or circuit breaker before inspecting, installing, maintaining, or servicing the Invenco OPT

# 2.4 Evacuation, Barricading and Shut-Off

Any procedures requiring accessing a pump/dispenser head requires the following three actions:

- An evacuation of all unauthorized persons and vehicles
- Using safety tape or cones as barricades to the effected units
- A total electrical shut-off of the affected unit(s)

#### 2.5 Read the Manual

Read, understand and follow this manual and any other labels or related materials supplied with the equipment. If you do not understand a procedure, call an Invenco Authorized Service Centre or Invenco



#### **Revision Number/Security level**

R06 S2

# Retrofit G6-300 / G6-400 + InvencoLink Wayne Helix (US and Canada) Standard Installation Guide

Service Officer. It is imperative to your safety and the safety of others to understand the procedures before beginning work.

#### Follow the Regulations 2.6

Regulations in OSHR (Occupational Safety and Health Regulations), national, state and local codes, including customer requirements must be followed. Failure to install, inspect, maintain or service this equipment in accordance with these codes, regulations and standards may lead to legal citations with penalties and may affect the safe use and operation of the equipment.

#### **Replacement Parts** 2.7

Use only genuine Invenco replacement parts and retrofit kits on your installation. Using parts other than genuine Invenco replacement parts could create a safety hazard and violate local regulations.

# 3 Safety Symbols and Terminology



This safety alert symbol is used in this manual and on warning labels to alert you to a precaution which must be followed to prevent potential personal safety hazard. Obey safety directives that follow this symbol to avoid possible injury or death.

#### **Signal Words**

These signal words used in this manual and on warning labels tell you the seriousness of particular safety hazards. The precautions below must be followed to prevent death, injury or damage to the equipment:

DANGER:	Alerts you to a hazard or unsafe practice which will result in death or serious injury
WARNING:	Alerts you to a hazard or unsafe practice that could result in death or serious injury
CAUTION:	Designates a hazard or unsafe practice which may result in minor injury, property or equipment damage

#### Working with Fuels and Electrical Energy



#### **Revision Number/Security level**

### Retrofit G6-300 / G6-400 + InvencoLink Wayne Helix (US and Canada) Standard Installation Guide

#### Prevent Explosions and Fires 3.1

Fuels and their vapors may explode or burn if ignited. Spilled or leaking fuels cause vapors. Even filling customer tanks will cause potentially explosive vapors in the vicinity of dispenser or island.

#### 3.1.1 No Open Flames



Open flames from matches, lighters, welding torches or other sources can ignite fuels and their vapors.

#### 3.1.2 No Sparks - No Smoking



Sparks from starting vehicles, starting or using power tools, burning cigarettes, cigars or pipes can also ignite fuels and their vapor. Static electricity, including an electrostatic charge on your body, can cause a spark sufficient to ignite fuels and their vapors. After getting out of a vehicle, touch the metal of your vehicle to discharge any electrostatic charge before you approach the dispenser island.

#### 3.1.3 Working Alone

It is highly recommended that someone who is capable of rendering first aid be present during servicing. Be familiar with Cardiopulmonary Resuscitation (CPR) methods if you are working with or around high voltages. This information is available from the First Aid training providers. Always advise the station personnel about where you will be working and caution them not to activate power while you are working on the equipment. Use the OSHA Tag-out/Lockout procedures. If you are not familiar with this requirement, refer to information in the relevant manual and OSHA documentation.

#### 3.1.4 Working with Electricity Safety

Ensure that you use safe and established practices in working with electrical devices. Poorly wired devices may cause a fire, explosion or electrical shock. Ensure that grounding connections are properly made. Take care that sealing devices and compounds are in place. Ensure that you do not pinch wires when replacing covers. Follow OSHA Tag-out/Lockout requirements. Station employees and service contractors need to understand and comply with this program completely to ensure safety while equipment is down.

For US: Follow all applicable requirements in NFPA 30, 30A and 70, and those of the Local Authority Having Jurisdiction for electrical wiring.

For Canada: Follow all applicable requirements in Canadian Electrical Code (CE Code), CSA C22.1.



#### 3.1.5 Hazardous Materials

Some materials present inside electronic enclosures may present a health hazard if not handled correctly. Be sure to clean hands after handling equipment. Do not place any equipment in mouth.

#### 3.1.6 In an Emergency

Compile the following information in case of emergency:

- Location of accident (e.g. address, front/back of building, etc.) •
- Nature of accident (e.g. possible heart attack, struck by a vehicle, burns, etc.) •
- Age of victim (e.g. baby, teenager, middle-age, elderly). •
- Whether or not victim has received first aid (e.g. stopped bleeding by application of pressure etc.) •
- Whether or not victim has vomited (e.g. if swallowed or inhaled something etc.) •

#### IMPORTANT:

Oxvgen may be needed at scene if gasoline has been ingested or inhaled. Seek medical advice immediately.

#### 3.1.7 Approvals

Invenco develops and maintains its hardware and software products using industry-standard quality processes, and is audited by various bodies.

The Invenco G6-300 / G6-400 OPT has UL File Reference of E469526 and E480135 and carries labels similar to this:



The Invence Retro-Fit Kit has UL File Reference of MH.61528



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# 3.2 Computer Programs and Documentation

All Invenco Group Ltd. computer programs (including software on discs and within memory chips) and documentation are copyrighted by, and shall remain the property of, Invenco Group Ltd. Such computer programs and documents may also contain trade secret information. The duplication, disclosure, modification, or unauthorized use of computer programs or documentation is strictly prohibited, unless otherwise licensed by Invenco Group Ltd.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# 4 Installation Guide

- 1. Please ensure all safety procedures are followed per requirement by the customer before installing the retrofit kit.
- 2. Remove power to Pump and follow the OSHA Lock-out/Tag-out procedures.



# WARNING

Failure to turn off the unit during installation of the kit may cause injury or bodily harm from electrical shock. Ensure that all power to the unit is switched off before opening the door of the unit and during kit installation.

3. This installation will require various panel replacements. The panels will be removed from the door and replaced with pre-built panels with the OPT modules pre-fitted.

### 4.1 Disassembly Procedure

<u>NOTE:</u> This installation guide is valid for Helix Standard Dispensers without an intercom speaker. Check and verify at pre-installation step 3 to confirm before proceeding further.

Before installation of the equipment can take place, the existing door assembly must be removed from the dispenser. This section covers the removal of these components including:

- Removal of reused components, e.g. PPU panel
- Unused cables and wires from door components

<u>Note</u>: Throughout this disassembly procedure there are many cable assemblies that will be unplugged and will not be reused. It is up to the discretion of the installer whether to remove these cables or position them inside of the dispenser cavity. The loose cables need to be bundled and restrained using zip-ties or cable restraints. After the cables have been bundled, they must be placed in a location that will not cause obstruction, exposure, or hazard.

**Note**: It may be necessary to disconnect cable assemblies on various boards during this disassembly procedure in order to more easily access other components. Disconnect these cables as necessary. It is recommended that the installer of this kit either re-connect these cables immediately afterwards or mark each disconnected cable before it is unplugged to make it easier to identify when it comes time for re-installation.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

- 4.2 Pre-Installation Procedure
- 4.2.1 Shut off the main power to the dispenser before beginning the deinstallation.
- 4.2.2 Open the dispenser.





Figure 1: Security Bolts



Document Number	DCV-00577	
Date Released	Feb. 2023	
Revision Number/Security level	R06 S2	
col ink Wayne Helix (US and Canada)		

2. Open the door and place the Prop Rod in the upper right corner to hold up the dispenser Collar Frame.



Figure 2: Door Prop Rod in position



 Check to verify that the dispenser does not have an existing intercom speaker. Visually identify to see if the intercom speaker is present on the upper plastic collar frame. If an intercom speaker is present, this installation guide does not cover installation in this dispenser. Close up the dispenser again and contact technical support for advice. Otherwise carry on with the next steps to complete the installation.



Figure 3: Intercom Speaker

- 4. Remove the lower metal Collar Frame
  - a. Unscrew the two attaching screws using a T7 Torex driver holding the upper and lower collar frame sections together. Retain the screws and set aside.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 4: Location of attaching screws, viewed from below

b. Using a flathead driver, leverage the plastic latch on the upper plastic frame away from the metal frame. Apply a sharp force to the bottom of the metal collar frame until the hooks disengage. Retain and set aside.



**Caution:** When the lower metal frame disengages from the upper plastic frame it could fall causing injury to the installer or damage to the frame itself. Hold in place to prevent injury or damage.

5. Repeat the previous steps to remove the Metal Collar Frame on the opposite side of the dispenser.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2
	<b>A</b> I \

#### 4.2.3 Remove the dispenser shoulders

1. With both plastic frames on each side closed, lift slightly until the shoulders can be removed.



Figure 5: Prying point



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

2. Pry up on the points indicated until the shoulder is loosened. Pull the rest of the way off.



Figure 6: Shoulder partially raised



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

3. Repeat the removal step on the other dispenser shoulder. Retain both shoulder sections.

Caution: Be careful to apply enough force to loosen the shoulder piece but not enough to snap off the capturing feature. These components will be reinstalled.



Figure 7: Shoulder raised further



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

4. Verify the upper plastic collar frame on each side of the dispenser is raised and the Prop Rod is in place after both shoulders have been removed.



Figure 8: Metal Collar Frame removed



#### 4.2.4 Uninstall the Helix Cabinet Components

1. Uninstall all components from the upper Plastic Collar Frame.

Note all connections to the Helix Customer Display. Unplug all connections to the Helix Customer Display and unscrew the grounding wire screw from the plastic collar frame using a T7 Torex driver. Retain the ground wire screw.



Figure 9: Note connections for later reinstallation



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

2. Unlock the Helix STD components using the site's assigned key.



Figure 10: Unlock the STD components



3. Uninstall the PPU panel.



a. Pull out the Helix STD components and PPU Panel attached to the slide rails.

Figure 11: Pull out the STD components

b. Note the cable connections to the PPU Board (located below the Helix STD components), PPU Grade Select Buttons Cable, Totalizer Cables, and Call/Intercomm Button cable for re-installation. Disconnect all cables from the PPU board, totalizers (if present), Grade Select Buttons, and Call Button (if present on PPU panel).



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2
and ink Mayna Halix (HC and Canada)	

Note: Up to 5 PPUs may be included depending on the configuration.



c. Note the location of each Totalizer Bracket Assembly. Remove and retain the Totalizer Bracket Assembly if present. Discard attaching hardware.



Figure 12: Location of totalizer bracket



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

d. Unscrew the metal PPU board bracket from the plastic PPU panel using a Philips head driver (or T7 Torex driver depending on screw type). Discard the hardware.



Figure 13: Location of PPU bracket screws

e. Remove the PPU board from the metal bracket. Retain the PPU board and attaching hardware. Discard the metal bracket.

Note: Depending on the PPU configuration, the PPU board could be held on by 2 to 5 screws to the metal bracket.



Figure 14: Location of PPU board screws



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

f. Disengage the three plastic securing latches at the top of the PPU panel and pull off the lower portion of the gasket attached around the edge of the PPU panel. Remove and retain the plastic PPU panel.



Figure 15: Location of PPU Panel latches and gasket



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

g. Remove and discard the string gasket from the PPU panel.



Figure 16: PPU Panel string gasket

- 4. Remove the Helix STD Components.
  - a. Unplug all cables included in the black sleeved cable bundle from the Helix STD components attached to the slide rail pull-out (Card Reader, Screen, etc.).



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 17: Black cable sleeve



Figure 18: Cables from sleeve to unplug



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

b. Open the printer door using the site assigned printer key and pull out the printer.



Figure 19: Printer door with lock



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

c. Unplug the printer cables from the printer unit.



Figure 20: Unclip printer cables

d. Unclip the Printer Cables from the routing channel along the side of the printer. Pull the cables through the printer door opening. Close and re-lock the printer door.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 21: Pull printer cables thru door opening

e. Check that all connections are unplugged from the Helix STD components (including grounding wires) and unzip the cable bundle from the STD slide bar and place into the dispenser.


Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 22: Unzip cable bundle from slide bar

f. Remove the Helix STD components by disengaging the slide bars and pulling the components fully out of the dispenser. Depress the plastic catch lever on each slide bar track and pull out the STD components until the slide bars clear the dispenser. Discard the Helix STD components.



Caution: The Helix STD Components are heavy and could come loose quickly. A second installer may be needed when removing the STD components off the slide track rails.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 23: Slide catch levers in two places (one per slide)



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

g. Remove both slide rails from inside the dispenser. Depress the red security latch on the back side of the slide rail and pull the track out of the dispenser slide rail. Discard the rails.





Figure 24: Remove the slide rails



- 5. Remove reused cables from the Black Sleeved Cable Bundle and remove unused cables from the dispenser.
  - a. Remove any restraints holding the Black Sleeve Cable Bundle to the inside of the dispenser and remove the Black Sleeve from the cable bundle. Discard the black sleeve.
  - b. Identify the PPU cables for power and communication, PPU Grade Select Cable, Totalizer Cables (if present), and Call/Intercomm Button cables (if present on the PPU panel) from the Cable Bundle. Retain these cables and their dispenser connections.
  - c. Cut all cable ties holding the bundle. Remove and discard all other cables from the dispenser.
- 6. Repeat the previous steps for the opposite side of the dispenser.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

#### 4.2.5 Uninstall the dispenser Upper Collar Frame



1. Disengage the prop rod from the collar frame.

Figure 25: Disengage the Prop Rod

2. Keep the dispenser frame in the open position while pushing the hinge tab out on the right side of the dispenser (The side closest to the prop rod).



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 26: Push the hinge tab out

3. Lift up on the collar frame until the hinge pin clears the hinge tab. Rest the right side of the frame on the dispenser.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 27: Hinge tab pushed out

- 4. Repeat the process on the left side hinge pin and hinge tab. Push out on the tab and lift up on the dispenser frame until the frame is removed from the dispenser.
- 5. Uninstall the Prop Rod Bracket.
  - a. Turn the Upper Collar frame on its side with the Prop Rod Bracket facing up.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 28: Prop Rod Bracket (silver)

b. Push up on the bracket while wiggling side to side until it clears the edge of the collar frame.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 29: Push and wiggle the Prop Rod Bracket

c. Continue to push up on the bracket until it is fully removed. Retain the Prop Rod Bracket.



6. Remove the Customer Display from the plastic collar frame. Unscrew the remaining three screws holding the Customer Display with a T7 Torex driver. Retain the display and attaching hardware.



Figure 30: Screw locations for Customer Display

- 7. Discard the plastic collar frame.
- 8. Repeat for the opposite side of the dispenser.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

#### 4.2.6 Uninstall the metal bracket components from the dispenser

- 1. Remove the metal cross bar bracket and attaching hardware from the dispenser.
  - a. Unscrew the two screws from the bracket.

**Note:** Detach any ground cables connected to the bracket at this time. Discard the attaching hardware.



Figure 31: Screw locations for Metal Bracket

b. Push in the catch on one side and firmly push up or use a rubber mallet on the underside of the bracket. Repeat the process on the other side of the bracket until both cleared their respective latches.

Note: The metal tab on the bracket may need to be bent with pliers or vice grips to clear the plastic catch.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 32: Screw location for Metal Bracket



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

c. Remove and discard the bracket and attaching hardware.



Figure 33: Metal Bracket loose in cabinet (bottom of image)

- 2. Repeat the previous steps for the opposite side of the dispenser.
- 3. Remove both bottom side metal brackets and attached components from the dispenser. Some components may need to be disconnected from cables. Discard the brackets and attached components.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 34: Bottom side metal brackets and components removed



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

- 4. Remove the Helix STD Payment Controller Board components.
  - a. Identify the board shown below.



Figure 35: Helix STD Payment Controller Board

b. Unplug all cables from the STD controller board.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 36: Location of Helix STD Payment Controller in the dispenser



c. Remove the STD controller board using a T7 Torex driver on the 4 corner screws holding the metal plates together.

**Note:** Unscrew the outside screws attaching the STD Controller Board Plate to the larger metal plate, not the board screw themselves. Pushing the screw from the back (the screw tip) may be necessary for the threads to engage on the larger plate.



Figure 37: Remove the Helix STD Payment Controller Board and Bracket

5. Remove the lower metal plate from the dispenser to access the large metal plate previously holding the STD payment controller board.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 38: Lower metal plate after removal



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

a. Unscrew the buzzer from the lower metal plate.



Figure 39: Buzzer on lower metal plate



b. Attach the buzzer to the Pump Controller Metal Panel using the supplied adhesive pad MP0999 (497-0521281).



Figure 40: Buzzer removed from lower metal plate



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

c. Remove the nuts on the bottom plate stud and any nuts holding a ground wire to the bottom plate. Discard all hardware.



Figure 41: Ground wires to be disconnected from lower metal plate



d. Using a pair of tin snips or hand cutters, cut the bottom plate on the side of the buzzer as shown below.

Caution: Before making the cut, clear all cables away in the path of the hand cutters.



Figure 42: Cutting point on lower metal plate, buzzer side



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

e. Behind the Pump Controller panel, cut the lower metal plate as shown below.



Figure 43: Cutting point on lower metal plate, behind Pump Controller Panel



Document Number	DCV-00577
Boodifient Namber	201 00011
Data Dalazza I	E.L. 0000
Date Released	Feb. 2023
Revision Number/Security level	R06.S2
Revision Number/Security level	100 02

f. Behind the Large Metal STD Payment Controller Board plate, cut the plate in the location below. Push on the plate until the cutter can get enough purchase on the plate.



Figure 44: Cutting point on lower metal plate, behind Payment Controller Board



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



g. Move to the opposite side of the dispenser and cut the metal plate in the location below.

Figure 45: Cutting point on lower metal plate, opposite side of dispenser

h. Once the plate is cut, bend down until the plate is pulled out of the dispenser side bosses holding it in place. You may also need to bend the Stud tabs up and out of the way with a flat head driver located on the right side of the panel on each side of the dispenser. Remove and discard the lower plate.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 46: Bend tabs upward, and plate downward to clear studs



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

6. Remove the remaining plate that held the STD payment controller board.a. Push from the back of the plate so it bulges towards you.



Figure 47: Press on plate to make it bulge for easier removal

- b. Continue to pull on the plate until it disengages from the dispenser side bosses. Remove the plate and discard.
- 7. Continue to the Installation Section.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

### 4.3 Install the G6-300 / G6-400 Assembly into the Wayne Helix

This section follows from the Disassembly procedure above, and assumes the pump is still open.

4.3.1 Prepare and Install the Helix Power Supply Assembly

Identify Side A and B by looking at the designation on the inside of the dispenser.



Figure 48: Identifying Side A

- 1. Attach both Power Supply Assemblies (PSU) (EZ0853) to the Helix PSU Mounting Bracket (MP0908 or 497-0517696).
  - a. Identify the stud wing on the PSU Assembly labeled "Ovation". Install the Helix PSU Mounting Bracket to this wing.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 49: Install Helix PSU Mounting Bracket

b. Install PSU Screw A (MS0249 or 006-8617819) into the back of the Helix PSU Mounting Bracket. Install the screw into the stud on one side and a PSU Screw B (MS0146 or 006-8611215) and nut (MN0076 or 006-8611426) assembly on the other side.



Figure 50: Install PSU screws A and B



c. Flip over and attach the second PSU Assembly to the Helix PSU Mounting Bracket with the 2 x MN0029 nuts on the "Ovation" wing.



Figure 51: Install second Helix PSU Assembly

d. Install the PSU Screw B (MS0146 or 006-8611215) and nut (MN0076 or 006-8611426) assembly into the location below.



Figure 52: Install PSU screw B



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

2. Install the Dispenser Invenco Link Converter to one of the PSU brackets. Follow the Invenco Link Installation Instructions (DCV-00465). Acquire the Invenco Link Retrofit Kit, UL Listed by Report Retrofit kit part number RF00033-XX.



Figure 53: InvencoLink installed on PSU Assembly for Side A

3. Install the Helix PSU Assembly with the Dispenser Invenco Link facing out towards you on the dispenser side opposite the pump controller board. Place the full Helix PSU Assembly into the dispenser cavity in the farthest back plastic bracket slots located in the center of the dispenser.



Figure 54: PSU Assemblies installed, showing orientation.



- 4. Connect Helix Power Adapter Cables (EK0126 or 497-0513686) to the Main AC power in line in the lower dispenser electronic cavity.
  - a. On Side A of the dispenser, identify the main AC power in line connected to the Power board in the lower left side of the dispenser.
  - b. Disconnect the main AC line.



Figure 55: Main AC power line to disconnect

c. Acquire the Helix power adapter cable. Plug in the pigtail end of the cable to the main AC line.



Figure 56: Plug in pigtail-end of Helix power adaptor cable



d. Connect the second Helix power adapter cable to the other pigtail end of the first connected cable.



Figure 57: Plug in second helix power adaptor cable

e. Connect the free pigtail end of the Helix power adapter cable to the Main Power Distribution Board connection previously disconnected.



Figure 58: Second Helix power adaptor cable plugged into board



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

- 5. Route both Helix Power Adapter Cables into the upper dispenser cavity.
  - a. On Side A of the dispenser, identify the cable routing duct in the lower right corner of the dispenser.



Figure 59: Cable-routing duct

b. Route the power adapter cables through the cable routing duct into the upper electronic cavity.

**Note:** Use a length of wire or twine to help route the cables up the duct. Drop the wire or twine into the top of the duct, wrap/tie the wire or twine to the cable and guide into and up the routing duct.



Figure 60: Twine/wire wrapped around connector to aid routing



- 6. Route the Helix Pump Comm Adapter Cable (EK0203 or 497-0519397) into the wiring duct. Only one Comm Adapter Cable is needed per dispenser.
  - a. Acquire the Helix Pump Comm Adapter Cable and drop the dispenser connection end (white 4 pin connector) into the right side from side B cable routing duct.



Figure 61: Drop cable into Cable-routing duct

b. Route the comm connection through the cable routing duct and pull out from the bottom.



Figure 62: Cable exiting duct at the bottom



Decument Number	
Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

c. Plug the four-pin connector to the comm pass through on the comm board.



Figure 63: Connect cable to the comm board

d. Plug in the green connector to the Dispenser Invenco Link.



Figure 64: Plug green connector into InvencoLink


7. Connect the preinstalled PSU power cables to the previously routed Helix power adapter cables.



Figure 65: Connect mains cable for each PSU Assembly

- 8. Install the CAT network cable, Yellow for LAN (EK0131 or 497-0513384), to the Dispenser Invenco Link.
  - a. Connect the Side A connection in the LAN 1(Yellow) connection. Route the Side A connections over the opposite side to the communications board installed on Side A



Figure 66: Connect Yellow cable for Side A



b. Connect the Side B connection in the LAN 2(Yellow) connection. Allow the B side network cables to fall into the B side dispenser cavity.



Figure 67: Connect Yellow and Red cables for Side B



#### 4.3.2 Install the Collar Frame

- 1. Acquire the Plastic Upper Collar Frame (MP0933 or 497-0517598). Install the retained Prop Rod bracket to the new plastic collar frame in the noted position from the uninstall process.
  - a. Place the retained Prop Rod Bracket into the new Plastic Collar Frame. Slide the end section into the gap indicated below.



Figure 68: Place Prop Rod Bracket



b. Push in the Prop Rod Bracket until the retaining feature engages and holds the Bracket in place.



Figure 69: Check bracket-retaining feature

2. Slide the new top plastic collar frame into the lower metal collar frame until the latches on each side engage.



Figure 70: Latch plastic collar frame into lower metal frame



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

3. Secure the upper and lower frame collars together with the retained screws.



Figure 71: Use retained screws on the collars

4. Place in the hinge pin section of the upper collar into the hinge



Figure 72: Placing hinge pin section



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

5. Install the other hinge pin into the hinge and apply force until the hinge engages onto the hinge pin.



Figure 73: Complete mounted collars



- 6. Repeat the previous steps for the opposite side of the dispenser.
- 7. Reinstall the dispenser shoulders over the hinges.
  - a. Both dispenser frames should be lowered and lifted until each shoulder piece on each side is in position.
  - b. Apply force to the top of each shoulder until it's seated into the top of the dispenser.



Figure 74: Apply force to seat the shoulders



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

c. Reopen the dispenser frames and engage the prop rods after both shoulders are reinstalled.



Figure 75: Re-open the frames using the Prop Rods



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

#### 4.3.3 Prepare to install the G6-300 / G6-400 Panel Assembly

- 1. Install the Customer Display onto the G6-300 / G6-400 Panel Assembly (RP00079-XX).
  - a. Install the Customer Display, noting the orientation is correct and upright with the retained screws. The fourth screw is with the customer display grounding wire.



Figure 76: Screw the Customer Display onto the panel

- 2. Prepare the PPU Panel and Slide Rails.
  - a. Install the retained PPU board onto the new metal PPU bracket (MP1000 or 497-0522916) using the retained hardware.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2
col ink Wayne Helix (LIS and Canada)	

**Note:** Depending on the PPU configuration, the PPU board could be held on by 2 to 3 screws to the metal bracket.



Figure 77: PPU Panel screw positions

b. Remove the two outside slide rail sections from the Helix STD slide rail and bracket assemblies (Printer Side Slide Rail, MZ0212; Card Reader Side Slide Rail, MZ0222 by pulling back on the plastic latches as shown below.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 78: Remove outside rail slide sections c. Install the slide rails into the dispenser on Side A. Push all the way in until the latch engages.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 79: Install slide rails into dispenser (Side A)

d. Additionally, fit the MS0280 screw for each bracket to further support the rail in position. Once the rails are slid in all the way until the latch engages as per the above, extend the rail fully to allow access to the screw hole on the base of the rail and fit the screw in place.





e. Rotate the remaining attached slide rails into position and secure with the pre-fitted screw and nut. Repeat on the opposite side.



Figure 80: Remaining slide rails

- 3. Combine the PPU and Slide Rail components to make the PPU Slide Rail Assembly.
  - a. Place the assembled PPU board and metal bracket onto the retained Plastic PPU plate.



Figure 81: PPU board and plate



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

b. If present place the Totalizer Bracket Assemblies in the previously noted location. Keep in place and install in between the PPU Bracket and Slide Rail Assembly. If no totalizers are present, use the supplied washer (MW0058 or 006-8626923) instead in the same location.



Figure 82: Totalizer Bracket Assembly in place



Figure 83: Washer in place of Totalizer Bracket Assembly



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

c. Attach the Printer Side Slide Rail onto the right side of PPU assembly with the screens facing away from you. Place the Slide Rail over the bracket and insert the screw MS0245 (or 006-8611475) into the top of the PPU Plate and metal bracket. Secure with the nut MN0078 (or 006-8611847) from the bottom.



Figure 84: Printer Side Slide Rail positioning

d. Secure with the pre-fitted Screw and Nut assembly in the location displayed below. The retained Totalizer Bracket or spacer washer (MW0058 or 006-8626923) should be in place at this time in the previously noted locations.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 85: Totalizer Bracket or Washer

e. Repeat on the Card Reader side to attach the Card Reader Side Slide Rail.



- 4. Install the Slide Rail and PPU assembly to the Helix G6-300 / G6-400 Panel Assembly (RP00079-XX).
  - a. Remove the 4 screw and nut assemblies from the Helix G6-300 / G6-400 Panel Assembly and retain.



Figure 86: Helix G6-300 / G6-400 Panel Assembly screw locations.



b. Place the PPU Plastic panel onto the bottom edge of the Helix Panel, making sure the gasket stays in place between the PPU and Helix panels.



Figure 87: Placing the PPU panel (top) onto the G6-300 / G6-400 panel assembly (bottom)

c. Adjust the brackets until the screw locations and panel holes align correctly. Check the fit and middle gasket position.



Figure 88: Adjust the PPU panel position



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

d. Install the previously removed screw and nut assemblies to attach the Slide Rail PPU assembly to the G6-300/ G6-400 panel assembly.



Figure 89: Reinstall the screws in four places

e. Install the bottom gasket around the PPU Plastic Plate. Start at the top edge of the PPU panel and work your way around to ensure a watertight seal.



Figure 90: Install the bottom gasket. Having a third hand may help

5. Repeat the previous steps for the second side's G6-300 / G6-400 Panel Assembly.



#### 4.3.4 Install the G6-300 / G6-400 Panel Assembly into the Helix STD Dispenser

1. Install the slide rails into the previously installed outer slide rails. Push the G6-300 / G6-400 Panel Assembly into the dispenser until the slide rail catches engage and the G6-300 / G6-400 Panel Assembly's gasket is flush against the dispenser edge. Check the seal.



Caution: Do not lift by the PPU panel. It is suggested to lift by the Metal Slide Rail Brackets.





Figure 91: Install the panel onto the slide rails

- 2. Repeat the previous step for the opposite side of the dispenser.
- 3. Pull out the G6-300 / G6-400 Panel Assembly. Install the power cable, network cable, and earth cable to the G6-300 / G6-400 OPT.

For The G6-400 OPT: Open the cover on the G6-400 unit to allow access to the connections.



- a. Plug the Black low-voltage DC cable, preinstalled on the PSU plate assembly into the OPT:
  - i. For the G6-300: Plug one of the DC cables into the OPT and leave the other one unplugged.
  - ii. For the G6-400: Plug both the DC cables into the OPT.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



G6-300 OPT

G6-400 OPT

b. Connect the EK0131 Yellow LAN cables into the correct sockets on the OPT. The port numbers on the InvencoLink for the cable (e.g. LAN-1) must match the side you're working on (e.g. Side A):



c. Clip the green earth cable, preinstalled on the PSU plate onto the ¼" tab on the G6-300 / G6-400 OPT:



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



G6-300 OPT

G6-400 OPT

Figures 92a, b and c (top to bottom): Sockets for Power, LAN and earth cables

4. Bundle the connected cables with a cable tie as shown.



G6-300 OPT

G6-400 OPT

Figure 93. Using a Cable Tie

For The G6-400 OPT: Closes the cover on the G6-400 unit.

5. Place an MF0046 cable clip on the G6-300 / G6-400 Panel Assembly as shown:



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 94. Location of cable clip

6. Further gather the cables and secure them to the cable clip using a cable-tie, taking care to form a U-shape as shown:



Figure 95. Cable tying to the clip

- Install the MZ0116 Isolating Cover over the rear of the G6-300 / G6-400 OPT, onto the G6-300 / G6-400 Panel Assembly.
  - a. Place the cover with the ground tab to the left over the G6-300 / G6-400 OPT, ensuring that no cables are snagged.
  - MZ0116 has captive screws for attachment. Insert and tighten the eight captive screws into the Stand-Offs on the G6-300 / G6-400 Panel Assembly, using a M3 nut socket driver:



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 96. Isolating Cover Installation

c. Plug an EK0130 Grounding Cable onto the tab on the left of the Isolating Cover:



Figure 97. Grounding Cable

- d. Gather EK0130 into the loom of cables.
- e. Attach the other end of the EK0130 cable to the PSU assembly grounding stud. Remove existing grounding nut, install the unconnected end of EK0130 cable and reinstall the nut. Repeat for the second EK0130 cable, installing the unconnected end of EK0130 cable to the same ground stud as the first EK0130 cable.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 98: All earth (ground) cables attached to the stud on the PSU plate

- f. Gather any excess wire of EK0130 and tidy it into the loom.
- 8. Push in the G6-300 / G6-400 Panel Assembly until the customer display cables and grounding wire can be connected or installed using the retained hardware.
  - a. Install the grounding wire and customer display cables to the customer display to the previously noted locations.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2
	1100 02



Figure 99: Install the Customer Display cables

9. Reconnect all PPU, Grade Select Button, totalizers (if present), and Call/Intercomm Button (if present on PPU panel) connections previously noted.



Figure 100: Reconnect PPU button, Grade-Select and Totalizer cables



- 10. Replace the dispenser frame lock if required (optional per installation site order). Located at the bottom of the metal dispenser frame.
  - a. Take out the old lock, remove the lock cam screw and cam. unscrew the lock barrel nut. Remove the lock and lock gasket.



Figure 101: Remove the existing lock completely

b. Install the new lock assembly MO0023 + MO0033 (497-0515297). Slide in the lock barrel and gasket. Install the lock barrel nut and tighten the lock into place. Install the new lock cam in the unlocked position with the bend towards the metal frame as shown below. Check to make sure the lock cam rotates up towards the cut away edge (the direction of the cam's point). Return to the open position and install the cam screw.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2



Figure 102: Install the supplied lock assembly. Note orientation



11. Route all cabling away from sharp edges, gaskets, and slide rails. Push the G6-300 / G6-400 Panel Assembly into its closed position against the dispenser frame and secure with the two prefitted 7/8" long captive screws.



Figure 103: Secure the panel to the dispenser



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

12. Lower the Frame Collar and lock into place by pulling down on the frame collar initially, then pushing down the top part with one hand and locking the bottom part in place with the other.



Figure 104. Closing the Dispenser

- 13. Repeat for Side B.
- 14. Return Power to the dispenser.



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

#### 4.3.5 Wiring Completion

Ensure that all cables are tidy and cannot become snagged or pinched when the door of the cabinet is opened and closed.

WARNING – Local regulations may also require that the installation be electrically tested and certified BEFORE switch-on.





Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

# 5 First Power-Up

Once the installation is complete and the wiring is certified (if necessary), power may be applied. The G6-300 / G6-400 OPT takes a couple of minutes to complete its start-up phase, during which several information screens will be presented.

The terminal will display the following screen whilst attempting to connect to the LAN. This screen will persist until a connection can be made:



If the terminal is successful in connecting to the LAN it will display the following screen and the rest of the start-up sequence will continue:





Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

The following steps describe the paper loading procedure.

Step	Description	Photo reference (G6-300)	Photo reference (G6-400)
1.	Ensure the paper roll has a neat cut edge.		
2.	Remove spindle from the paper holder position. Note orientation of the spindle (handle to left)	Spindle	
3.	Insert roll in place – the paper tension flap is spring-loaded so you will need to apply some pressure. Insert the spindle through the middle of the roll to hold in place.		



Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2





Document Number	DCV-00577
Date Released	Feb. 2023
Revision Number/Security level	R06 S2

Use the paper-feed buttons to advance the paper through the terminal until it appears at the paper exit chute.

7. paper exit chute. Cut the paper using both paperfeed buttons, then remove the cut length from the chute.



