

Maintenance

Service Codes

GENERAL	
Action Taken	Code
Reprogrammed TLS	0101
Cold Boot System	0102
Replaced PC Board / Software	0103
No Problem Found	0104
No Solution Found	0105
Other Solution Performed	0106
Replaced Keyboard	0107
Replaced Display	0108
Preformed System Upgrade	0109
Conducted Training	0110
Operator Error	0111

SYSTEM	
Action Taken	Code
Installed Paper	0201
Replaced Printer	0202
Replaced Line Sharing Device	0203
Cleared Paper Jam	0204

TANKS	
Action Taken	Code
Dispatched/ Removed Water	0301
Preformed Precision Tank Test	0302
Rewired/Reconnected Probe	0303
Replaced Probe	0304
Stuck Float Corrected	0305
Cleaned Probe	0306
Corrected Tank Chart	0307
Reset AccuChart	0308

SENSORS	
Action Taken	Code
Replaced Sensor	0401
Rewired Sensor	0402
Dispatched / Removed Fuel	0403
Dispatched / Removed Water	0404
Adjusted Brine Level	0405
Repaired Primary Leak	0406
Repaired Secondary Leak	0407
Recharged Vacuum	0408
Replaced Vacuum Tubing	0409

COMMUNICATIONS	
Action Taken	Code
Added Com Board	0501
Reset Modem	0502
Reconnected Phone Line	0503
Reprogrammed Phone Number	0504
Reprogrammed IP Address	0505
Replaced Com Cable	0506

DIMs	
Action Taken	Code
Replaced DIM Module	0601
Replaced DIM Cable	0602
DIM Misapplication	0603
Switched CAB Box to "Run Mode"	0604

Note: User defined service codes are 99XX.

LINE LEAK DETECTION	
Action Taken	Code
Repair Leak	0701
Repaired STP Motor / Capacitor	0702
Restore STP Power	0703
Cleaned Functional Element	0704
Disabled Functional Element	0705
Out of Fuel	0706
Replaced LLD Transducer	0707
Rewired LLD	0708
Replaced LLD Module	0709
Replaced Check Valve	0710
Replaced Product Relay	0711
Replaced Dispenser Valve(s)	0712
Eliminated WPLLD Noise Source	0713
Installed Mechanical LLD	0714
Performed Line Test	0715
Replaced MLLD	0716

SUBMERSIBLE PUMP	
Action Taken	Code
Installed new STP	0801
Replaced UMP	0802
Replaced Functional Element	0803
Replaced Check Valve	0804
Reprogrammed IP Address	0805
Replaced Control Box/ Relay	0806
Replaced Capacitor	0807
Replaced Seals	0808
Replaced Variable Speed Controller	0809
Rewired Pump	0810

VLLD ALARMS	
Action Taken	Code
Replaced VLLD Controller	0901
Replaced VLLD Check Valve	0902
Ran VLLD Self Check	0903
Ran VLLD Pump Self Test	0904
VLLD other Corrective Action	0905

STAGE II VAPOR RECOVERY	
Action Taken	Code
Calibrated Vac Assist Pump	1001
Conducted A/L Test	1002
Back Pressure Test	1003
2" Decay Test	1004
10" Decay Test	1005
Repaired Containment Leak	1006
Repaired Vac Assist Pump	1007
Replaced Vac Assist Pump	1008
Adjusted A/L	1009
Serviced Vapor Processor	1010

STAGE I VAPOR RECOVERY	
Action Taken	Code
Repaired / Replaced Spill Bucket	1101
Repaired / Replaced Delivery Cap	1102
Repaired / Replaced Vapor Extractor Cap	1103
Repaired / Replaced Probe Riser Cap	1104

Note: User defined service codes are 99XX.

DISPENSER	
Action Taken	Code
Replaced Filter	1201
Replaced Software	1202
Cold Boot System	1203
Repaired / Replaced Dispenser	1204
Reset Shear Valve	1205
Replaced Shear valve	1206
Repaired Piping	1207
Repaired / Replaced Boot	1208
Calibrated Liquid Meter(s)	1209
Replaced Printer	1210
Installed Paper	1211
Cleared Paper Jam	1212
Replaced/Repaired Door Lock	1213
Replaced/Repaired Door Switch	1214

HANGING HARDWARE	
Action Taken	Code
Replaced Hanging Hardware	1301
Replaced Nozzle	1302
Replaced Boot	1303
Replaced Spout	1304
Replaced Primary Hose	1305
Replaced Breakaway	1306
Repaired Breakaway	1307
Replaced Whip Hose	1308
Replaced Hose Extractor	1309
Replaced Flow Limiter	1310
Replaced Nozzle Cover	1311
Bagged Off Nozzle	1312
Returned Nozzle to Service	1313

POS	
Action Taken	Code
Reprogram	1401
Replace Software	1402
Cold Boot System	1403
Replace POS	1404
Rewire POS	1405

FACILITY MAINTENANCE	
Action Taken	Code
Repaired / Replaced Outside Lights	1501
Repaired / Replaced Signage	1502
Cleaned Storm Drain	1503
Serviced Oil Water Separator	1504

INSPECTION / TESTING	
Action Taken	Code
Annual Operability Testing	1601
Weight and Measures Testing	1602
Sump Integrity Testing	1603
Designated Operator Visit	1604
ELD Testing	1605
Spill Bucket Testing	1606

Note: User defined service codes are 99XX.

