

Introduction

Purpose

This manual provides instructions for installing the Encore®, Ecometer™ Check Valve Kit (K96623-03) on Encore Ecometer units and includes instructions when to install the Ecometer Discharge Adapter (M07297B001) provided in the kit.

Meter Check Valve Kits - Comprehensive Listing

Part Number	Description	Products	Reference Document
K94254-01	Meter Check Valve Retrofit Kit, The Advantage®	The Advantage	MDE-3243
K94254-02	Meter Check Valve Kit, Eclipse®	Eclipse	MDE-3243
K96623-01	Meter Check Valve Kit, Encore	Encore Standard and Atlas®	MDE-3243
K96623-02	Meter Check Valve Kit, Encore, Flex Fuels	Encore Flex Fuels	MDE-3243
K96623-03	Meter Check Valve Kit, Encore Ecometer	Encore Ecometer	MDE-5198

Note: The above table represents all the check valve kits for positive displacement meter applications (all C and V style meters).

Table of Contents

Topic	Page
Introduction	1
Important Safety Information	3
Before You Begin	5
Removing Existing Ecometer	6
Installing Encore, Ecometer Check Valve Kit	7

Required Tools and Materials

The following tools and materials are required for installing the Encore, Ecometer Check Valve Kit:

- Hexagonal Nut Driver Set
- Pliers
- Phillips® and Flat-blade Screwdrivers
- Socket Wrenches
- Silicone Grease
- Fuel Collector Cup (K35493)
- Torque Wrench
- Absorbent Towels

Parts List

The following table lists the parts included in the Encore, Ecometer Check Valve Kit:

Item #	Description	Part Number	Quantity
1	Assembly, Meter Check Valve, Plated	N23619-G4	1
2	Discharge Adapter, Ecometer	M07297B001	1
3	O-ring, 1.234 X 139 X 0.139, Viton®	N16891-41	1
4	O-ring, 1.609 X 139 X 0.139, Viton A	N16891-33	1
5	O-ring, 48 X 3, Ecometer	M08023B001	2

Required Reading



Before installing this kit, the installer must read, understand, and follow:

- This manual
- National Fire Protection Association (NFPA) 30A, The Automotive and Marine Service Station Code
- NFPA 70®, The National Electrical Code (NEC®)
- Applicable federal, state, and local codes and regulations

Failure to do so may adversely affect the safe use and operation of the equipment.

Note: These kits must be installed by a Gilbarco®-trained Authorized Service Contractor (ASC) to ensure warranty.

Related Documents

Document Number	Title	GOLD SM Library
MDE-3802	Encore and Eclipse Site Preparation Manual	<ul style="list-style-type: none"> • Site Prep • Encore and Eclipse • Encore and Eclipse Installers • Footprint and Elevations
MDE-3804	Encore and Eclipse Start-up/Service Manual	<ul style="list-style-type: none"> • Encore and Eclipse • Service Manual
TRP-2710	New Check Valve Enters Production Service Bulletin	N/A

Abbreviations and Acronyms

Term	Description
ASC	Authorized Service Contractor
GOLD	Gilbarco Online Documentation
NEC	National Electrical Code
NFPA	National Fire Protection Association
OSHA	Occupational Safety and Health Administration
STP	Submersible Turbine Pump

Important Safety Information

Notes: 1) *Save this Important Safety Information section in a readily accessible location.*

2) *Although DEF is non-flammable, Diesel is flammable. Therefore, for DEF cabinets that are attached to Diesel dispensers, follow all the notes in this section that pertain to flammable fuels.*

This section introduces the hazards and safety precautions associated with installing, inspecting, maintaining, or servicing this product. Before performing any task on this product, read this safety information and the applicable sections in this manual, where additional hazards and safety precautions for your task will be found. Fire, explosion, electrical shock, or pressure release could occur and cause death or serious injury, if these safe service procedures are not followed.


Preliminary Precautions


You are working in a potentially dangerous environment of flammable fuels, vapors, and high voltage or pressures. Only trained or authorized individuals knowledgeable in the related procedures should install, inspect, maintain, or service this equipment.

Emergency Total Electrical Shut-Off

The first and most important information you must know is how to stop all fuel flow to the pump/dispenser and island. Locate the switch or circuit breakers that shut off all power to all fueling equipment, dispensing devices, and Submerged Turbine Pumps (STPs).

⚠ WARNING

 The EMERGENCY STOP, ALL STOP, and PUMP STOP buttons at the cashier's station WILL NOT shut off electrical power to the pump/dispenser. This means that even if you activate these stops, fuel may continue to flow uncontrolled.

 You must use the TOTAL ELECTRICAL SHUT-OFF in the case of an emergency and not the console's ALL STOP and PUMP STOP or similar keys.

Total Electrical Shut-Off Before Access

Any procedure that requires access to electrical components or the electronics of the dispenser requires total electrical shut off of that unit. Understand the function and location of this switch or circuit breaker before inspecting, installing, maintaining, or servicing Gilbarco equipment.

Evacuating, Barricading, and Shutting Off

Any procedure that requires access to the pump/dispenser or STPs requires the following actions:



- An evacuation of all unauthorized persons and vehicles from the work area
- Use of safety tape, cones, or barricades at the affected unit(s)
- A total electrical shut-off of the affected unit(s)

Read the Manual

Read, understand, and follow this manual and any other labels or related materials supplied with this equipment. If you do not understand a procedure, call the Gilbarco Technical Assistance Center (TAC) at 1-800-743-7501. It is imperative to your safety and the safety of others to understand the procedures before beginning work.

Follow the Regulations

Applicable information is available in National Fire Protection Association (NFPA) 30A; *Code for Motor Fuel Dispensing Facilities and Repair Garages*, NFPA 70; *National Electrical Code (NEC)*, Occupational Safety and Health Administration (OSHA) regulations and federal, state, and local codes. All these regulations must be followed. Failure to install, inspect, maintain, or service this equipment in accordance with these codes, regulations, and standards may lead to legal citations with penalties or affect the safe use and operation of the equipment.

Replacement Parts

Use only genuine Gilbarco replacement parts and retrofit kits on your pump/dispenser. Using parts other than genuine Gilbarco replacement parts could create a safety hazard and violate local regulations.

Federal Communications Commission (FCC) Warning

This equipment has been tested and found to comply with the limits for a Class A digital device pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy, and if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense. Changes or modifications not expressly approved by the manufacturer could void the user's authority to operate this equipment.

Safety Symbols and Warning Words

This section provides important information about warning symbols and boxes.

Alert Symbol



This safety alert symbol is used in this manual and on warning labels to alert you to a precaution which must be followed to prevent potential personal safety hazards. Obey safety directives that follow this symbol to avoid possible injury or death.

Signal Words

These signal words used in this manual and on warning labels tell you the seriousness of particular safety hazards. The precautions below must be followed to prevent death, injury, or damage to the equipment:



DANGER: Alerts you to a hazard or unsafe practice which will result in death or serious injury.



WARNING: Alerts you to a hazard or unsafe practice that could result in death or serious injury.



CAUTION with Alert symbol: Designates a hazard or unsafe practice which may result in minor injury.

CAUTION without Alert symbol: Designates a hazard or unsafe practice which may result in property or equipment damage.

Working With Fuels and Electrical Energy Prevent Explosions and Fires

Fuels and their vapors will explode or burn, if ignited. Spilled or leaking fuels cause vapors. Even filling customer tanks will cause potentially dangerous vapors in the vicinity of the dispenser or island.

DEF is non-flammable. Therefore, explosion and fire safety warnings do not apply to DEF lines.

Important Safety Information

No Open Fire



Open flames from matches, lighters, welding torches, or other sources can ignite fuels and their vapors.

No Sparks - No Smoking



Sparks from starting vehicles, starting, or using power tools, burning cigarettes, cigars, or pipes can also ignite fuels and their vapors. Static electricity, including an electrostatic charge on your body, can cause a spark sufficient to ignite fuel vapors. Every time you get out of a vehicle, touch the metal of your vehicle, to discharge any electrostatic charge before you approach the dispenser island.

Working Alone

It is highly recommended that someone who is capable of rendering first aid be present during servicing. Familiarize yourself with Cardiopulmonary Resuscitation (CPR) methods, if you work with or around high voltages. This information is available from the American Red Cross. Always advise the station personnel about where you will be working, and caution them not to activate power while you are working on the equipment. Use the OSHA Lockout/Tagout procedures. If you are not familiar with this requirement, refer to this information in the service manual and OSHA documentation.

Working With Electricity Safely

Ensure that you use safe and established practices in working with electrical devices. Poorly wired devices may cause a fire, explosion, or electrical shock. Ensure that grounding connections are properly made. Take care that sealing devices and compounds are in place. Ensure that you do not pinch wires when replacing covers. Follow OSHA Lockout/Tagout requirements. Station employees and service contractors need to understand and comply with this program completely to ensure safety while the equipment is down.

Hazardous Materials

Some materials present inside electronic enclosures may present a health hazard if not handled correctly. Ensure that you clean hands after handling equipment. Do not place any equipment in the mouth.

WARNING

The pump/dispenser contains a chemical known to the State of California to cause cancer.

WARNING

The pump/dispenser contains a chemical known to the State of California to cause birth defects or other reproductive harm.

In an Emergency

Inform Emergency Personnel

Compile the following information and inform emergency personnel:

- Location of accident (for example, address, front/back of building, and so on)
- Nature of accident (for example, possible heart attack, run over by car, burns, and so on)
- Age of victim (for example, baby, teenager, middle-age, elderly)
- Whether or not victim has received first aid (for example, stopped bleeding by pressure, and so on)
- Whether or not a victim has vomited (for example, if swallowed or inhaled something, and so on)

WARNING



Gasoline/DEF ingested may cause unconsciousness and burns to internal organs. Do not induce vomiting. Keep airway open. Oxygen may be needed at scene. Seek medical advice immediately.

WARNING

DEF generates ammonia gas at higher temperatures. When opening enclosed panels, allow the unit to air out to avoid breathing vapors. If respiratory difficulties develop, move victim away from source of exposure and into fresh air. If symptoms persist, seek medical attention.

WARNING



Gasoline inhaled may cause unconsciousness and burns to lips, mouth, and lungs. Keep airway open. Seek medical advice immediately.

WARNING



Gasoline/DEF spilled in eyes may cause burns to eye tissue. Irrigate eyes with water for approximately 15 minutes. Seek medical advice immediately.

WARNING



Gasoline/DEF spilled on skin may cause burns. Wash area thoroughly with clear water. Seek medical advice immediately.

WARNING

DEF is mildly corrosive. Avoid contact with eyes, skin, and clothing. Ensure that eyewash stations and safety showers are close to the work location. Seek medical advice/recommended treatment if DEF spills into eyes.

IMPORTANT: Oxygen may be needed at scene if gasoline has been ingested or inhaled. Seek medical advice immediately.

Lockout/Tagout

Lockout/Tagout covers servicing and maintenance of machines and equipment in which the unexpected energization or start-up of the machine(s) or equipment or release of stored energy could cause injury to employees or personnel. Lockout/Tagout applies to all mechanical, hydraulic, chemical, or other energy, but does not cover electrical hazards. Subpart S of 29 CFR Part 1910 - Electrical Hazards, 29 CFR Part 1910.333 contains specific Lockout/Tagout provision for electrical hazards.

Before You Begin

Read and understand all safety information found in *MDE-3804 Encore and Eclipse Start-up/Service Manual*.

CAUTION

A clean work area is a requirement for this procedure. It is imperative that no contamination be allowed to enter the Ecometer assembly. Use absorbent towels to clean surface during this procedure.

Meter lockup due to the introduction of contaminants is not covered under warranty.

To prepare the site and dispenser for the installation, proceed as follows:

- 1 Inform the manager.
- 2 Barricade the unit to be worked on.
- 3 Remove power to the unit at the breaker panel and all associated STPs and blenders. Follow OSHA lockout/tagout procedures.
- 4 Match the parts received in the kit with [“Parts List”](#) on [page 2](#).

WARNING

Failure to turn off the unit during kit installation may cause injury or bodily harm from electrical shock. Ensure that all power to the unit is switched off before opening the door to the unit and during kit installation.

Testing Two-stage Valves

Testing two-stage valves for leaks is necessary to make sure the valves remain closed (not leaking) when not engaged.

To test the valves for leaks, proceed as follows:

Note: To determine if a valve leaks, the line must be pressurized, the valve must be deactivated, and the nozzle must be opened. If the meter turns, the valve is leaking and must be replaced or rebuilt before proceeding.

- 1 Place the nozzle into approved container before activating.
- 2 Apply line pressure while the valve is deactivated. This can be done two ways:
 - The coil of the valve being tested can be removed or disconnected and then the nozzle handle associated with that valve can be engaged. This will turn on the STP and apply line pressure. (This would normally open the valve, which is why it has been disconnected.).
 - The STP of the grade being tested can be activated by engaging the nozzle handle on the opposite side of the pump from the valve being tested. Then the nozzle can be opened and the meter checked to determine if any leakage is occurring. For example, to test mid-grade side A valve, turn on mid-grade side B (flip side B nozzle handle), open mid-grade side A nozzle and observe mid-grade side A meter.

- 3 Observe meter for one minute. If the meter rotates, replace or rebuild the Two-stage Valve (R19093-02) using the Solenoid Repair Kit.
- 4 After all valves have been tested, proceed to [“Removing Existing Ecometer”](#).

Removing Existing Ecometer

To remove the existing Ecometer, proceed as follows:

Note: Read and follow all safety precautions in [“Important Safety Information”](#) on [page 3](#).

- 1 Remove the outer and inner side sheathings.
- 2 Close and test all shear valves on dispensers to check that they seal mechanically.
- 3 Press **CLEAR** then **ENTER** on the manager keypad.
- 4 Open the nozzle into approved container to bleed pressure. Some residual pressure may remain.
- 5 Remove the Ecometer discharge line flange and meter inlet line flange bolts.
Note: Support the Ecometer when removing bolts.
- 6 Remove the Ecometer bracket bolts.
Note: It is not necessary to remove the bracket.

Installing Encore, Ecometer Check Valve Kit

To install the Encore, Ecometer Check Valve Kit, proceed as follows:

Note: Check if the Ecometer Discharge Flange (M08513B010) has a “notch” as shown in [Figure 1](#). If yes, discard the Ecometer Discharge Adapter (M07297B001) supplied with this kit and install Meter Check Valve Assembly (N23619-G4) directly into the Ecometer discharge flange along with the O-rings.

- 1 Remove existing O-rings and meter check valve assembly (see [Figure 3](#) on [page 8](#)).
- 2 Inspect and clean the discharge plate and the discharge line mounting surface.

Figure 1: Modified Ecometer Discharge Flange (M08513B010) and Ecometer Discharge Adapter (M07297B001)




Figure 2: Vertical Mounting of Meter






Figure 3: Dismantling Meter Assembly



- 3 Lubricate the two large M08023B001 O-rings with silicon grease. Insert N16891-41 and N16891-33 O-rings into the groove in Encoder Ecometer (M07299B001).

- 4 Lubricate and insert the smallest N16891-41 O-ring into the groove in Ecometer Discharge Plate [M07512B001 (see [Figure 3](#) on [page 8](#))].

Figure 4: Assembling Check Valve



- 5 Insert the meter check valve assembly into the Ecometer discharge adapter.
Note: Ensure the check valve spins freely in the outlet flange so that there is no interference (to ensure that proper outlet flange is used).
- 6 Lubricate and insert the N16891-33 O-ring into the groove in the Ecometer discharge adapter, (see [Figure 4](#)).
- 7 Assemble the unit which was prepared in step 3 on [page 8](#) by using the four Metric Socket Head Cap Screws M6 X 50 (M07620B001).
- 8 Bolt the Ecometer assembly to mounting brackets and pipeline flanges.

The following tables provide torque specification for screws and bolts, pipe plugs and pipes, flanged and compression tube fittings, self-contained pumping units and meter bolts:

Screws and Bolts (Plated)

Recommended torque		
Screw/Bolt	in-lbs	kg-m
#2	2.0 - 2.3	0.02 - 0.03
#3	3.0 - 3.4	0.03 - 0.04
#4	4.5 - 5.4	0.05 - 0.06
#5	6.3 - 7.2	0.07 - 0.08
#6	9.0 - 10.0	0.10 - 0.14

Recommended torque		
Screw/Bolt	in-lbs	kg-m
#8	16.0 - 18.0	0.18 - 0.21
#10	26.0 - 29.0	0.30 - 0.33
1/4	4.5 - 5.4	0.62 - 0.75
5/16	4.5 - 5.4	0.62 - 0.75
7/16	4.5 - 5.4	0.62 - 0.75
1/2	4.5 - 5.4	0.62 - 0.75

Pipe Plugs and Pipes

Recommended torque		
Screw/Bolt (in inches)	in-lbs	kg-m
1/8	11 - 12	1.50 - 1.65
1/4	22 - 35	3.0 - 3.5
3/8	36 - 40	5.0 - 5.5
1/2	49 - 54	6.8 - 7.5
3/4	70 - 78	9.7 - 10.8
1	101 - 112	14.0 - 15.5
1 1/4	139 - 154	19.2 - 21.3
1 1/2	190 - 211	26.3 - 29.2
2	270 - 300	37.3 - 41.5

Completing Installation

To complete installing the Encore, Ecometer Check Valve Kit, proceed as follows:

- 1 Replace the side sheathing.
- 2 Open the shear valves.
- 3 Turn on the unit and STP power.
- 4 Purge air 25 gallons (95 liters) and check for leaks.
- 5 Calibrate the meter.

Installing the Encore, Ecometer Check Valve Kit is now complete.

The Advantage® Series, Eclipse®, Encore®, and Gilbarco® are registered trademarks of Gilbarco Inc. Atlas® is a registered trademark of Gasboy International. Ecometer™ is a trademark of Gilbarco Inc. GOLDSM is a service mark of Gilbarco Inc. NEC® and NFPA 70® are registered trademarks of the National Fire Protection Association. Phillips® is a registered trademark of Phillips Screw Company. Viton® is a registered trademark of DuPont Performance Elastomers LLC.

