



## INSTALLATION INSTRUCTIONS 4-INCH PETROLEUM & CHEMICAL CONDUIT SEAL KIT

Part No. 144-087-5, Part No.144-089-5, Part No.144-163-5, Part No.144-201-5

The following defined terms are used throughout this literature to bring attention to the presence of hazards of various risk levels, or to important information concerning the life of the product.

**DANGER** indicates presence of a hazard which *will* cause *severe* personal injury, death or substantial property damage if ignored.

**WARNING** indicates presence of a hazard which *can* cause *severe* personal injury, death or substantial property damage if ignored.

**CAUTION** indicates presence of a hazard which *will* or *can* cause *minor* personal injury, death or substantial property damage if ignored.

**NOTICE** indicates special instructions on installations, operation, or maintenance which are important but not related to personal injury hazards.


This package contains:

- 2 each — Screws
- 2 each — Lock Washers
- 1 each — Top Plate, 1-3/32 inch diameter
- 1 each — Conduit Bushing
- 1 each — Bottom Plate, 1 inch diameter

Select the proper conduit seal bushing and assemble as shown.

**NOTICE**

**Selecting the proper bushing is important. If the bushing does not seal snugly around the wires when compressed, leakage of product around the wires can occur. This will lead to filling of the capacitor cavity with product.**



by  VEEDER-ROOT

125 Powder Forest Drive • Simsbury, CT 06070  
Tel: (860) 651-2700 • Fax: (860) 651-2719

041-785-1 Rev. E