



7300 West Friendly Avenue  
PO Box 22087  
Greensboro NC 27420-2087  
United States

[www.gasboy.com](http://www.gasboy.com)  
[www.veeder.com](http://www.veeder.com)

# Memorandum

---

To: Gasboy Distributor and ASC Principals (Canada) Date: June 18, 2010  
Ref: Canadian Electric Code Change affecting 2-wire installation  
From: Richard Browne, Vice President of Marketing, North America

---

As our installation partners you play a critical role in our customers' adherence to applicable regulatory requirements. Our dispenser Site Preparation Manuals state that all site preparation procedures must be made in accordance with NFPA 30A, NFPA 70, and applicable national, state, and local codes/regulations. In addition, for a non-US installation, other codes may apply.

For installations in Canada the applicable code is CSA C22.1, The Canadian Electric Code ("CEC"). The British Columbia Safety Authority recently issued a decision that the current wiring diagrams which show the two wire data cables and AC cables in the same conduit do not comply with the requirements for communication wiring as specified in CEC rule 60.

As a result, until further notice, installation of 2 wire data wiring must be run in separate conduit from the AC wiring for Gasboy 8800 model pumps and dispensers installed in Canada.

We are executing a review of this decision with the British Columbia Safety Authority, in accordance with their governing laws and procedures. We are confident that there are no safety concerns in relation to the procedure as described in the wiring diagrams, as there is isolation provided by the distribution box and dispenser. The same procedure is allowed by the National Electrical Code in the United States. Nevertheless, until such time as this issue is resolved to the satisfaction of Canadian authorities, any new dispenser installations made in Canada must be made with the 2 wire field wiring in separate conduit from the AC field wiring.

We will update you following completion of our review with the British Columbia Safety Authority or should we become aware of any other significant information. Thank you for your support.