

## Capacitor Kit



**DANGER!** Always DISCONNECT and LOCK or TAG OUT the power before starting to service the pump.

### Purpose of Capacitor Kit

---

This kit is required when upgrading Red Jacket standard packer or competitor's pump with Red Jacket 2HP UMP. Note, this kit is for use with a standard control only, not with IQ Control Box™ or Smart Controller™.

**CAUTION!** Due to the differences in designs, it is critical that the proper capacitor is used.

### Procedure

---

1. Follow the manufacturer's instructions for replacement of UMP (unit - motor pump) assembly.
2. If upgrading a Red Jacket standard pump, install 40 MFD capacitor kit part number 144-372-5 (can size 1 3/4" diameter x 3 3/4" height).
3. If upgrading a competitor's pump, install 40 MFD capacitor kit part number 144-373-5 (can size 2" diameter x 2 7/8" height).
4. Follow the instructions provided with the capacitor for removal and installation.
5. Reinstall the pump per manufacturer's instructions