



Evaluation of the Red Jacket Fx1DV and Fx2DV for Hourly Testing on Flexible Pipelines Containing Diesel Fuel

(Addendum to the March 1994 Evaluation)

PREPARED FOR

The Marley Pump Company
(A United Dominion Company)

March 11, 1999



Ken Wilcox Associates, Inc.
1125 Valley Ridge Drive, Grain Valley, MO 64029, USA
Voice (816) 443-2494, Fax (816) 443-2495
E-mail info@kwaleak.com, Web <http://www.kwaleak.com>

**Evaluation of the
Red Jacket Fx1DV and Fx2DV
for Hourly Testing on Flexible
Pipelines Containing Diesel Fuel**

(Addendum to the March 1994 Evaluation)

PREPARED FOR

The Marley Pump Company

(A United Dominion Company)

500 East 59th Street

Davenport, IA 52807

March 11, 1999

Preface

The data contained in this report was obtained from the Red Jacket Fx1DV/Fx2DV line leak detector installed in a standard Red Jacket submersible pump on flexible piping containing diesel fuel. This report is to be used in conjunction with the March 14, 1994 evaluation of the Fx1, Fx2, Fx1V and Fx2V on rigid pipelines containing gasoline.¹ Testing was performed in accordance with the EPA Pipeline Leak Detection Test Protocol² with the exception of the number of tests performed. The results of this abbreviated testing indicate that Red Jacket system will successfully perform leak detection on flexible pipeline systems containing diesel fuel. All testing was conducted at the Fuels Management Research Center (FMRC) operated by Ken Wilcox Associates, Inc.

This report was prepared by Mr. Jeffrey K. Wilcox, Ken Wilcox Associates, Inc. Questions regarding this addendum should be directed to Mr. Ed Dunning, Marley Pump, at (319) 391-8600.

KEN WILCOX ASSOCIATES, INC.



Jeffrey K. Wilcox
Project Engineer

Approved:



H. Kendall Wilcox, Ph.D.
President

March 11, 1999

¹ Evaluation of the Red Jacket Fx1, Fx2, Fx1V and Fx2V Line Leak Detectors For Hourly Monitoring on Rigid Pipelines, Final Report, Prepared for Marley Pump, March 14, 1994 (Revised July 24, 1995), Ken Wilcox Associates, Inc.

² "Standard Test Procedures for Evaluating Leak Detection Methods: Pressurized Pipeline Leak Detection Systems", EPA/530/UST-90/010, September, 1990.

Table of Contents

<u>Section</u>	<u>Page No.</u>
Preface	ii
1.0 Introduction	1
2.0 Background	2
3.0 Description of the Red Jacket System	3
4.0 Overview of the Evaluation Procedures and the Testing Conditions	4
5.0 Description of the Testing Location	6
6.0 Test Results	7

FX1DV/Fx2DV Addendum Flexible Pipelines with Diesel

1.0 Introduction

This report is to be used in conjunction with the March 14, 1994 evaluation of the Red Jacket Fx1, Fx2, Fx1V and Fx2V on rigid pipelines containing gasoline.³ The March 14, 1994 evaluation was conducted on a rigid pipeline that was 350 ft. in length by 3 3/8 inches in diameter with a volume of 181 gallons. Testing conducted on the rigid pipeline determined that the Red Jacket system had a probability of detection (P_D) of 100% and a probability of false alarm (P_{FA}) of 0% for Hourly Testing on bulk pipelines containing diesel fuel.

This report contains additional test data for the Red Jacket system that was conducted on a 215 ft, 1.5 inch diameter (internal) flexible pipeline with a capacity of 19.7 gallons. Testing was performed in accordance with the EPA Pipeline Leak Detection Test Protocol⁴ with the exception of the number of tests performed. The results of this abbreviated testing indicate that the Red Jacket Fx1DV/Fx2DV line leak detector will successfully perform hourly testing leak detection on flexible pipeline systems containing diesel fuel.

³ Evaluation of the Red Jacket Fx1, Fx2, Fx1V and Fx2V Line Leak Detectors For Hourly Monitoring on Rigid Pipelines, Final Report, Prepared for Marley Pump, March 14, 1994 (Revised July 24, 1995), Ken Wilcox Associates, Inc.

⁴ "Standard Test Procedures for Evaluating Leak Detection Methods: Pressurized Pipeline Leak Detection Systems", EPA/530/UST-90/010, September, 1990.

2.0 Background

The federal Environmental Protection Agency (EPA) has provided a series of documents⁵ which describe the procedures which are to be used to verify that leak detection equipment meets the performance requirements of the Federal Register.⁶ At the minimum, a leak detector which is capable of detecting leaks of 3.0 gallons per hour (gal/hr) or larger on an hourly basis must be installed on all pressurized piping. Other options include the use of equipment which is capable of detecting 0.20 gal/hr on a monthly basis or an annual test capable of detecting leaks of 0.10 gal/hr. The probability of detecting a leak of stated size must be 95% or greater with a probability of a false alarm (declaring a tight line to be leaking) of no more than 5%.

To provide a mechanism for achieving compliance with the requirements for leak detection on pressurized piping, the EPA has developed a test protocol "Standard Test Procedures for Evaluating Leak Detection Methods: Pressurized Pipeline Leak Detection Systems", EPA/530/UST-90/010, September, 1990. Testing conducted for this addendum were evaluated according to the EPA protocol with the exception of the number of tests conducted.

The EPA protocol does not require that systems be tested on both rigid and flexible pipelines. However, some federal, state, and local regulators have required additional testing on flexible pipelines for systems that were originally evaluated on rigid pipelines. This addendum has been prepared for Marley Pump to demonstrate the performance of this system on flexible pipelines containing diesel fuel.

⁵ "Standard Test Procedures for Evaluating Leak Detection Methods," EPA/530 UST-90/001-7, March to October 1990. Seven different procedures were developed for different leak detection methods and released between March and October 1990.

⁶ 40CFR Part 280, Subpart D.

3.0 Description of the Red Jacket System

The Fx1DV and Fx2DV leak detectors are mechanical systems that incorporate a poppet valve and metering pin. When the pump is activated, fuel is metered into the line to raise the pressure. If the pressure rises above 15 psi, the poppet valve opens and full flow into the line occurs. If the pressure fails to rise above 15 psi, fuel flow in the line is restricted to approximately 2 gal/min.

The model used to collect the data used in this report was the Fx2DV. Both the Fx1DV and Fx2DV that this report is applied to function in the same manner. Both are designed to operate in diesel fuel and contain a 1/4 inch FNPT threaded port in the cap of the leak detector. The Fx2DV also provides a 1/4 inch FNPT port in the body allowing for the "Snap Tap" option.

4.0 Overview of the Evaluation Procedures and the Testing Conditions

Six additional tests were conducted on the Red Jacket system. The test conditions and results for these six tests are provided in Table 1. A brief summary of the test procedures is below.

- Product is heated or cooled in the conditioning tank.
- Product is circulated through the pipeline for 1 hour.
- A leak is introduced into the pipeline either before or immediately after the product circulation ends.
- The leak detector conducts a test and the results are recorded

Testing was conducted with leak rates equivalent to 3 gal/h at 10 psi (for Hourly Testing). Testing was conducted at the temperature extremes of ± 25 deg F and at neutral. The ± 25 deg F temperature differences are the extremes required for EPA certification. If a leak detector is successful at these temperature differences, it would also be expected to pass at less extreme temperature differences.

**FX1DV/Fx2DV Addendum
Flexible Pipelines with Diesel**

Table 1. Data and Results for Testing Conducted on Flexible Pipelines Containing Diesel Fuel

Test No.	Date Test Began	Time Circulation Started	Time Circulation Ended	Time Data Collection Began	Time Data Collection Ended	Duration of Circulation	Time Between End of Circulation and Start of Data Collection	Duration of Data Collection	T(TB) (Product Temp.)	T(G) (Ground Temp.)	T(TB)-T(G) Temp. Differential)	Temp. Matrix Category	Induced Leak Rate	Measured Test Result
	mm/dd/yy	hhmm	hhmm	hhmm	hhmm	hhmm	hhmm	hhmm	deg F	deg F	deg F	deg F	gal/h	
1	01/05/99	1530	1630	1630	1631	0100	0000	0001	14.72	43.36	-28.64	<-25	3.0	Leak
2	01/05/99	1530	1630	1630	1631	0100	0000	0001	14.72	43.36	-28.64	<-25	0	Tight
3	01/06/99	0935	1035	1035	1036	0100	0000	0001	45.50	42.18	3.32	-5 to +5	3.0	Leak
4	01/06/99	0935	1035	1035	1036	0100	0000	0001	45.50	42.18	3.32	-5 to +5	0	Tight
5	01/06/99	1045	1145	1145	1146	0100	0000	0001	69.08	42.58	26.50	>+25	3.0	Leak
6	01/06/99	1045	1145	1145	1146	0100	0000	0001	69.08	42.58	26.50	>+25	0	Tight

5.0 Description of the Testing Location

The Red Jacket system was evaluated at the Fuels Management Research Center which is located in Grain Valley, Missouri and operated by Ken Wilcox Associates, Inc. All line tests were conducted with diesel fuel in the pipeline. Testing for this addendum was conducted on a 215 ft. long flexible pipeline with a total volume of 19.7 gallons. The bulk modulus of the flexible pipeline was 4,485 psi.

The Red Jacket system was installed by the manufacturer in its usual configuration in a standard Red Jacket pump. The Red Jacket pump was installed in a 600 gallon tank where product was thermally conditioned according to the EPA protocol requirements. Product was heated or cooled in the 600 gallon tank by circulating glycol and product through an external heat exchanger. Soil temperatures were monitored by temperature sensors located at 2 inches, 4 inches and 12 inches from the line as specified by the protocol. A single temperature sensor was located 4 inches from the bottom of the product conditioning tank. The weighted soil temperature and the product tank temperature at the beginning of the test were used to compute the temperature differential between the soil and the product.

6.0 Test Results

The performance parameters for the Red Jacket system are summarized in Table 2.

Probability of Detection (P_D)

The Red Jacket system was correct in its determination of a leak for all of the leak tests. The estimated P_D of a 3 gal/h leak is 100% with an upper confidence limit of 63 to 100%.

Probability of False Alarm (P_{FA})

The Red Jacket system was correct in its determination of a tight pipeline for all of the tight tests. The estimated P_{FA} is 0% with a lower confidence limit of 0 to 37%.

Time to Conduct a Test

All of the tests were completed in one minute or less.

Maximum Line Size

The EPA protocol allows pipeline leak detection methods to be used on pipelines with up to twice the volume of that used in the evaluation. If the EPA protocol is used to calculate the performance parameters, the Red Jacket system can be used on flexible pipelines up to 39.5 gallons.

Table 2. Summary of the Test Results and Limitations

Parameter	Value
Probability of Detection for a 3 gal/h leak	100%
Confidence Limits	63 to 100%
Probability of False Alarm	0%
Confidence Limits	0 to 37%
Time to Conduct a Test	less than one minute
Maximum Applicable Flexible Line Size	39.5 gallons
